



Region:	Trentino Alto Adige						Archetype code: RES_SINGLE_1971-1980_E_TN	
Building category:	Residential buildings-Single family							
Period of construction:	1971-1980							
Climatic zone:	E	Number of records:				2310		
Description (the codes associated with walls and slabs refer to the structures described in UNI/TR 11552:2014): External walls: no data available Roof slabs: no data available							Data sources: APE (100%)	
	Data	Symbol	Unit of measure	Mean value	Standard deviation	Q1 (first quartile)	Median value	Q3 (third quartile)
BUILDING GEOMETRY	Number of floors	n_f	-	-	-	-	-	-
	Gross height	H_g	m	-	-	-	-	-
	Footprint area	$A_{\text{footprint}}$	m ²	-	-	-	-	-
	Heated gross floor area	$A_{H,g}$	m ²	-	-	-	-	-
	Heated net floor area	$A_{H,n}$	m ²	122	73	90	100	122
	Heated gross volume	$V_{H,g}$	m ³	-	-	-	-	-
	Heated net volume	$V_{H,n}$	m ³	501	665	327	372	471
	Compactness ratio	$A_{\text{env}}/V_{H,g}$	m ⁻¹	0.61	0.20	0.45	0.64	0.73
	WWR – North orientation	WWR_N	-	-	-	-	-	-
	WWR – South orientation	WWR_S	-	-	-	-	-	-
	WWR – East orientation	WWR_E	-	-	-	-	-	-
	WWR – West orientation	WWR_W	-	-	-	-	-	-
	Window to useful floor area ratio	A_{wi}/A_{use}	-	-	-	-	-	-
ENVELOPE	Roof type	-						
	U-value of the roof	$U_{\text{fl;up}}$	W/(m ² ·K)	-	-	-	-	-
	External walls type	-						
	U-value of the wall	U_{wl}	W/(m ² ·K)	-	-	-	-	-
	Slab on ground floor type	-						
	U-value of the floor	$U_{\text{fl;lw}}$	W/(m ² ·K)	-	-	-	-	-
	Windows type	-						
	U-value of the windows	U_{W}	W/(m ² ·K)	-	-	-	-	-
GAINS and VENTILATION	Shading system type	-						
	Occupancy density *	O_c	person/m ²	UNI EN 16798-1 - Table A.19				
	Lighting power density *	W_L	W/m ²	UNI EN 16798-1 - A.8.3				
	Equipment power density *	W_A	W/m ²	UNI EN 16798-1 - A.8.3				
	Type of ventilation	Natural: 100%						
THERMAL SYSTEMS	Air exchange rate *	n	h ⁻¹	0.30	-	0.30	0.30	0.30
	Heating system type	Unknown: 77%, Autonomous: 19%, Centralized: 4%						
	Heating generator	Traditional boiler: 34%; Condensing boiler: 30%, Boiler (unknown type): 22%, DHC: 5%, Unknown: 5%, LPG: 2%, Solid biomass:1%, Air source heat pump: 1%						
	Daily operating time of the heating system *	t_H	h	14	-	14	14	14
	Energy carrier	Natural gas: 79%, District heating: 11%, Unknown:6%, Gas Oil: 2%, Electricity: 2%						
	Heating emission sub-system	-						
	Cooling system type	Unknown: 96%, Absorption chiller: 4%						
	Daily operating time of the cooling system *	t_C	h	-	-	-	-	-
	Cooling emission sub-system	-						
	DHW system type	Autonomous – coupled with heating: 46%, Unknown: 35%, District heating: 11%, Autonomous - detached from heating: 5%, Centralized – coupled with heating: 3%						
	DHW generator	Natural gas boiler: 56%, , Unknown: 38%, Electric boiler: 3%, Electric heat pump: 2%, Solar thermal: 1%						
* These values were not available in the considered sources, and are thus derived from UNI EN Standards								

Region:	Trentino Alto Adige	Archetype code: RES_SINGLE_1971- 1980_E_TN
Building category:	Residential buildings-Single family	
Period of construction:	1971-1980	
Climatic zone:	E	
Number of records:		2310


Numerical variables – GEOMETRY



Numerical variables – ENVELOPE




Numerical variables – GAINS, VENTILATION and SYSTEMS USAGE



The data can be used for analysis, modeling, and research purposes, as long as it remains unaltered in its original form. Users are free to publish results based on the data, provided they credit the original source.

Region:	Trentino Alto Adige			Archetype code: RES_SINGLE_1971- 1980_E_TN
Building category:	Residential buildings-Single family			
Period of construction:	1971-1980			
Climatic zone:	E	Number of records:	2310	

ADDITIONAL DATA								
	Data	Symbol	Unit of measure	Mean value	Standard deviation	Q1 (first quartile)	Median value	Q3 (third quartile)
THERMAL SYSTEMS	Heating efficiency or <i>COP</i>	$\eta_{H,gen}$ or $COP_{H,gen}$	-	This value has to be retrieved from suitable datasheets				
	Total heating power	$P_{H,gen}$	kW	115	181	25	31	151
	Cooling efficiency or <i>EER</i>	$\eta_{C,gen}$ or $EER_{C,gen}$	-	This value has to be retrieved from suitable datasheets				
	Total cooling power	$P_{C,gen}$	kW	14	35	3	4	6
	Temperature of DHW	ϑ_W	°C	40	-	40	40	40
	DHW system power	$P_{W,gen}$	kW	115	181	25	31	151




Region:	Trentino Alto Adige	Archetype code: RES_SINGLE_1971- 1980_E_TN
Building category:	Residential buildings-Single family	
Period of construction:	1971-1980	
Climatic zone:	E	
Number of records:		2310

Additional data: other numerical variables that are not included in the archetype


DHW SUPPLY TEMPERATURE




SYSTEM POWER




CO₂ EMISSION



HEATING SYSTEM INSTALLATION YEAR



NON-RENEWABLE PRIMARY ENERGY USE



RENEWABLE PRIMARY ENERGY USE

